




01926 855205  EMAIL US  DONATE <[HTTPS://LOCALGIVING.ORG/DONATION/TKC](https://localgiving.org/donation/tkc)>

theKenilworthCentre  
we're here for you

< <https://www.thekenilworthcentre.com/>>

## Protected: Health & Safety

---

 <b>Same</b>	 <b>Same</b>	 <b>Better</b>
Previous Status	Current Status	Working Towards

### Fire Safety Report

Fire door strips have been replaced where needed.

LM and Vic have renewed any missing the Fire Door strips, weekly health and safety logs are to be completed by AK.

Fire Door to large community room does not have fire door seals, looking to source and install.

We need to pay to have a fire safety inspection which will tell us precisely what is required, and check over the whole building.

Under the stairs is under constant review, as area should be clear – AK is monitoring.

Fire doors should not be propped open, door stops have been removed.

See Governance and Policy report for updates on RA and Health and Safety Docs.

Hedges and nettles at the side (public walkway) are slowly being trimmed and cut back and monitored.



© The Kenilworth Centre - Charity No. 1144518 | Companies Ref. 7798716